

Ans-1200-3



Nagpal Associates

ARCHITECTS, ENGINEERS & VALUERS

Nand Kumar Nagpal
M.Sc. (Hons.) Maths
B.E. (Hons.) Civil
M.Tech. (Structure)
Govt. Approved Valuer for Income Tax,
Gift Tax, Wealth Tax (Cat:U/423 of 1999)
Fellow Member of Institution of Valuers (F-19737)
Member of Institution of Engineers (India) (M-142075-5)
Chartered Engineer (India) (M-142075-5)

Res.: 629, Sector-4, U.E., Gurgaon
Ph.: 0124-4116294 • M. 09810116294
E-mail: valuernagpal@yahoo.co.in
nagpalassociates@gmail.com

March 28, 2016

- 1. Name of the Customer : Texmaco Infrastructure & Holdings Limited
- 2. Description : Structural Stability of Porta Cabins in Birla Senior Secondary School, Kamla Nagar, Delhi-11007
- 3. Location : Kamla Nagar, Delhi-110007

TO WHOMSOEVER IT MAY CONCERN

This is to certify that the School Building is designed as per IS: 800: "General Construction in Steel -Code of Practice". The basic load of the subject structure meets or exceed the climatic data as published in 1987 edition of IS:875 (Part-3): "Code of Practice of design loads for building and structure".

The building is designed in accordance with the following governing code, structural load and design criteria:

IS: 800

Structure Use	Secondary structure for wall panels
Dead Load	15kg/m2 Puff Panel Weight + Frame Weight
Wind Speed	47m/sec
Live Load	IS: 875
Seismic Criteria	Zone V as per IS 1893:2002
Structural Steel Material	IS: 2062
Design of Building	25 Years

The Structure components have been properly erected in accordance with erection drawings as supplied and using the components as furnished, will meet the above loading requirement.

0124-4116294
NAND KUMAR NAGPAL
Institution of Engineers
(M-142075-5)
Gurgaon

Stamp: Nagpal Associates, Chartered Engineer, dated 28/3/2016

On the Panel of Hon'ble High Court of Delhi, Punjab National Bank, Canara Bank, UCB Bank, State Bank of India, Oriental Bank of Commerce, Sarva Haryana Gramin Bank, IFCL ...